

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Rechargeable Li-ion Battery System

Name and address of the applicant

DYNES DIGITAL ENERGY TECHNOLOGY CO., LTD.
Building 1&2, 7th–8th Floors, Building 3, No. 56-58 Nanhu Road, Chengnan
Subdistrict, Wuzhong District, Suzhou City, Jiangsu Province, China

Name and address of the manufacturer

DAQIN NEW ENERGY TECHNOLOGY (TAIZHOU) CO., LTD.
No.511 West Chenzhuang Road, Sanshui Street, Jiangyan District, 225500
Taizhou City, Jiangsu Province, China

Name and address of the factory

DAQIN NEW ENERGY TECHNOLOGY (TAIZHOU) CO., LTD.
No.511 West Chenzhuang Road, Sanshui Street, Jiangyan District, 225500
Taizhou City, Jiangsu Province, China*When more than one factory*☐ Additional information on page 2

Ratings and principal characteristics

Product data – type Stack 280-10S
Ratings: 512 Vdc, 280 Ah, 143,36 kWh

Product data – type Stack 280-11S
Ratings: 563,2 Vdc, 280 Ah, 157,70 kWh

Product data – type Stack 280-12S
Ratings: 614,4 Vdc, 280 Ah, 172,03 kWh

Product data – type Stack 280-13S
Ratings: 665,6 Vdc, 280 Ah, 186,37 kWh

Product data – type Stack 280-14S
Ratings: 716,8 Vdc, 280 Ah, 200,70 kWh

Product data – type Stack 280-15S
Ratings: 768 Vdc, 280 Ah, 215,04 kWh

Product data – type Stack 280-2S
Ratings: 102,4 Vdc, 280 Ah, 28,67 kWh

Product data – type Stack 280-3S
Ratings: 153,6 Vdc, 280 Ah, 43 kWh

Product data – type Stack 280-4S
Ratings: 204,8 Vdc, 280 Ah, 57,34 kWh

Product data – type Stack 280-5S
Ratings: 256 Vdc, 280 Ah, 71,68 kWh

Product data – type Stack 280-6S
Ratings: 307,2 Vdc, 280 Ah, 86,02 kWh

Product data – type Stack 280-7S
Ratings: 358,4 Vdc, 280 Ah, 100,35 kWh

Product data – type Stack 280-8S
Ratings: 409,6 Vdc, 280 Ah, 114,69 kWh

Product data – type Stack 280-9S
Ratings: 460,8 Vdc, 280 Ah, 129,02 kWh

This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V.
Meander 1051
6825 MJ Arnhem
Netherlands

Date: 2026-04-28

Signature: Kreny Lin



Ref. Certif. No.

NL-125403

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

Trademark / Brand (if any)

DYNESS

Customer's Testing Facility (CTF) Stage
used

Model / Type Ref.

Stack 280-10S, Stack 280-11S, Stack 280-12S, Stack 280-13S,
Stack 280-14S, Stack 280-15S, Stack 280-2S, Stack 280-3S,
Stack 280-4S, Stack 280-5S, Stack 280-6S, Stack 280-7S, Stack 280-8S
and Stack 280-9S

Additional information

☐ Additional information on page 2A sample of the product was tested and
found to be in conformity with

IEC 62619:2022

As shown in the Test Report Ref. No.
which forms part of this Certificate

6242300.50

This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V.
Meander 1051
6825 MJ Arnhem
Netherlands

Date: 2026-04-28

Signature: Kreny Lin